

SECCRA Community Landfill

SUPPLY HDPE PIPE 2023

SECCRA Community Landfill

219 Street Rd

West Grove, PA 19390

ADDENDUM No. 1

February 2, 2023

- A. Addendum No. 1** is issued as part of the Contract Document, to inform and/or specify changes, which take precedence over information contained in the original Contract Documents. Unless otherwise specifically noted or specified hereinafter, or shown on drawings or schedules accompanying this Addendum, all work required by this Addendum shall conform to the applicable provisions of the Contract Documents. **It shall be the responsibility of the Respondent to include in their proposal any cost implications of this Addendum. All Respondents are to indicate on the form of proposal submitted by them, acknowledgement of receipt and compliance with the contents of this Addendum No. 1.**
- B.** Any provision in any of the Contract Documents, which may be in conflict or be inconsistent with the contents of this Addendum, shall be void to the extent of such conflict or inconsistency.
- C.** The following clarifications/answers are provided in response to questions provided by potential bidders:
- C.1.** The pipe and fittings shall be IPS standard.
- C.2.** The butterfly valve shall be Asahi type 57 (or approved equal) with nitrile seat.

END ADDENDUM NO. 1